

STATEMENT OF CONFORMITY

Certificate No.: 10000473956-PA-DNV-IND

Project Nr: PRJN-268365-2021-PA-IND Validity:

15, December 2021 to 14, December 2024

This certificate consists of 4 pages

This is to certify that the Functional Safety Capability of

Ball Valve

as per table shown in Page 2 of this certificate

Manufactured by:

Intervalve Poonawalla Ltd.

UNIT II, S.NO.32B, HADAPSAR INDUCTRIAL ESTATE PUNE - 411013

has on a voluntary basis been assessed and found to confirm to the Functional safety standards and sub-clauses:

IEC 61508:2010 Parts 1 to 7

The above products and its associated data contained herein can be considered for use in the design of safety functions up to and including

SIL 3

When used in accordance with the scope and conditions of this certificate.

The Safety Integrity Level (SIL) relates to the complete safety System, not the individual elements, therefore this certificate only demonstrates the capability of the product to be implemented into a safety system of a required integrity level as defined above.

Further details are given in the following pages

Place and date: Chennai 15.12.2021

Check Validity

For the issuing office: DNV Business Assurance India Pvt Ltd

Hariharan Sundareswara Iyer Manager- Product Assurance



Certificate No.: 10000473956-PA-DNV-IND Place and date: Chennai, 15, December 2021

Revision No.: 0.0

Certificate history:

| Revision | Description | Issue Date |
|----------|----------------------|------------|
| 0.0 | Original Certificate | 2021-12-15 |

Products covered by this Statement:

| Product Name | Ball Valve |
|----------------------|--|
| Product types & size | Floating Ball Valve 2 way/ 3 way – ½"-12" Trunnion Mounted Ball Valve – 2 way 2"-30" and 3 way 2"-12" |

Applied Standards:

IEC 61508:2010 Parts 1 to 7

Product Details:

Safety function under consideration: As per SIL Safety Case Report SC268365-01

Architectural constraints: HFT: 1

Random Hardware Failure Rates (FIT): As per below Table 3 & 4

Table 3: Field Experience Data

| Product | Working Hours from | Working Hours until | Cumulated Working hours | Total Failure Hours |
|-------------|--------------------|---------------------|-------------------------|---------------------|
| Ball Valves | 8.4.2014 | 31.8.2021 | 8142439440 | 1726 |

Table 4: PFD Calculation using Field Experience Data

| Product | Cumulated working hours | Dangerous Failures considered | Dangerous undetected failure rate | PFD _{avg} (On Low Demand mode) |
|-------------|-------------------------|-------------------------------|---|---|
| Ball Valves | 8142439440 | 1726 | 2.12 E-07 | 9.3E-04 for HFT=0 9.4E-05 for HFT=1 |



Certificate No.: 10000473956-PA-DNV-IND Place and date: Chennai, 15, December 2021

Revision No.: 0.0

Hardware Safety Integrity Compliance [1]

Systematic Safety Integrity Compliance

Capability [2]

Overall SIL Capability Achieved [3]

Route 2_H

NA as per clause 7.4.2 of IEC 61508 Part 2 Systematic

SC 3

SIL 3 (for HFT=1)/SIL 2 (for HFT=0)

Information supporting the failure data

1. Product ID : As per Page 2

2. Functional specification : As per SIL Safety Case Report SC268365-01

3. Environmental Limits : NA

4. Lifetime / Replacement Limits : 20 Years

5. Maintenance Requirements : As detailed in Safety manual

6. Diagnostic Coverage : NA7. Diagnostic Test interval : NA

8. Evidence of use in similar conditions : NA



^[1] According to IEC 61508:2010 Part 2 Clause 7.4.2, 7.4.3 & 7.4.4

^[2] According to IEC 61508:2010 Part 4 Clause 3.5.9

^[3] Lowest SIL indicated



Certificate No.: 10000473956-PA-DNV-IND Place and date: Chennai, 15, December 2021

Revision No.: 0.0

Conditions of Safe Use

- 1. User shall comply with the detail contained in the manufacturer user manual as well as the information provided above.
- 2. Selection of this equipment for use in a safety application shall only be made by a competent person.
- 3. The collection of any data associated with this type for equipment during operations shall be collected and reported to the manufacturer
- 4. The product should be tested at regular intervals to identify any malfunctions in accordance with the product safety manual.

Conditions of Certificate

- 1. This certificate is based on the assessment carried out by DNV as recorded in assessment reports; SIL Safety Case SC268365-01
- 2. Printed copies of the certificates are not a controlled version.
- 3. This certificate is based on the contract, (Project No. PRJN-268365-2021-PA-IND), agreed between DNV and Intervalve Poonawalla Ltd.
- 4. Intervalve Poonawalla Ltd. shall ensure the Management of Functional Safety is maintained.
- 5. DNV shall be notified of any changes to the product that may impact on this certificate during the period of validity.
- 6. The use of this certificate is subject to the 'certificate agreement' for Functional Safety Certification.
- 7. This certificate remains the property of DNV and shall be returned upon request.

The following may render this statement invalid:

- Changes in the quality system affecting production.
- Periodical audits not held within the allowed time window.

END OF STATEMENT